

**BUILDING SAFETY CERTIFICATE**

No.9A/BSC/VJA/EC12025

Dated:30.07.2025

It is certified that existing building Chitturi Vidyalayam, Door No:21-122/15, Pantakaluva Road, Gollapudi - 521225 is having blocks(s) /Floor(s) as per details below:

Details of Block(s) in School	Block (1)	Block (2)	Block (3)	Block (4)	Block (5)	Block (6)
No.of Floor(s) in the Block	G+3	G				

The building is owned/occupied by Chitturi Vidyalayam, Door No:21-122/15, Pantakaluva Road, Gollapudi - 521225 have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of ...Dy. Executive Engineer (R&B) Buildings Sub-Division, Vijayawada.... (Name of Department/ Govt.) on 30-07-2025 (date of inspection) in the presence of Sri. Chitturi. Anandarama Sudhakar (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy for running school with effect from 30-07-2025 to 29-07-2028. For a period of Three years in accordance with rule and subject to compliance of the specific conditions as appended.

- 1.
- 2.
3. } Satisfied
- 4.

Issued on .....30-07-2025..... at .....2.30P.M..... by

\* Strike out whichever is not applicable. In case of block is more than six use separate sheet for detail.



Signature with Seal: *[Handwritten Signature]* Executive Engineer (R&B) Division

Name: VIJAYAWADA

Designation: \_\_\_\_\_

Name & Address of Department/ Office: *[Handwritten]*

*[Handwritten Signature]*

Secretary & Correspondent  
**CHITTURI VIDYALAYAM**  
 21-122/15, Panta Kaluva Road,  
 Gollapudi -521225,  
 NTR Dt., Andhra Pradesh.

**For CHITTURI VIDYALAYAM**

*[Handwritten Signature]*  
**PRINCIPAL**

2

## STRUCTURAL SOUNDNESS CERTIFICATE

1	Address of the School/College	:	CHITTURI VIDYALAYAM (Sri Chitturi Venkateswara Rao Trust) Door No.21- 122/15,Panta Kaluva Road,Gollapudi, VIJAYAWADA-521225
2	College/School Running in	:	RCC framed structure
3	No. of Floors	:	<b>BLOCK-I , G+3 Floors</b>
4	Stilt Floor/ground floor used as	:	Stilt floor available and in ground floor office and class rooms
5	Constructed in the year	:	2024
6	Constructed as per approved plan	:	Yes
7	Present period up to which certificate is in force	:	-
8	Any cracks developed in the walls in superstructure and basement.	:	No
9	Condition of lintels and walls above the lintel.	:	Good
10	Condition of beams and the Trusses	:	Good
11	Development of Cracks	:	Nil
12	Exposed reinforcement if any	:	Nil
13	Condition of Doors, Windows	:	Good
14	The width of the staircase flight is	:	1.61mts
15	Tread width is	:	0.27 mts
16	The height of rise	:	0.12 mts
17	The height of railing	:	0.75mts
18	Height of Corridor Parapet wall	:	1.1mts
19	Doorway dimensions	:	D = 1.05x2.1m
20	Height of Parapet wall	:	0.9mts
21	Internal corridor width	:	2.45m
22	Any Cantilever corridors	:	nil
23	Number of Exits	:	one
24	There is high tension electricy lines passing near to the building	:	-
25	There is Petrol/Gas stations near to the school	:	-
26	Building Plan submitted	:	Yes,Plan enclosed
27	Building Foundation and structural design submitted	:	-
28	Building was last painted in the year	:	new construction

Certified that the CHITTURI VIDYALAYAM (Block-I) building structure is fit to run educational institution and this certificate is valid for the period of three year i.e from 17-02-2025 to 16-02-2028

*[Signature]*  
17/2/2025  
Assistant Executive Engineer  
(R&B) City Roads Section  
Vijayawada



*[Signature]*  
17-2-25  
Executive Engineer  
(R&B) Division, Vijayawada.

*[Signature]*  
Secretary & Correspondent  
**CHITTURI VIDYALAYAM**  
21-122/15, Panta Kaluva Road,  
Gollapudi -521225,  
NTR Dist., AP

**For CHITTURI VIDYALAYAM**


*[Signature]*  
R&B

3


### STRUCTURAL SOUNDNESS CERTIFICATE


1	Address of the School/College	CHITTURI VIDYALAYAM (Sri Chitturi Venkateswara Rao Trust) Door No.21-122/15,Panta Kaluva Road,Gollapudi, VIJAYAWADA-521225
2	College/School Running in	RCC framed structure
3	No. of Floors	<b>BLOCK-2 , Stilt+1 Floor</b>
4	Stilt Floor/ground floor used as	Stilt floor available and in ground class rooms
5	Constructed in the year	2024
6	Constructed as per approved plan	Yes
7	Present period up to which certificate is in force	-
8	Any crakes developed in the walls in superstructure and basement.	No
9	Condition of lintels and wails above the lintel.	Good
10	Condition of beams and the Trusses	Good
11	Development of Cracks	Nil
12	Exposed reinforcement if any	Nil
13	Condition of Doors, Windows	Good
14	The width of the staircase flight is	1.61mts
15	Tread width is	0.27 mts
16	The height of rise	0.12 mts
17	The height of railing	0.75mts
18	Height of Corridor Parapet wall	1.1mts
19	Doorway dimensions	D = 1.05x2.1m
20	Height of Parapet wall	0.9mts
21	Internal corrridor width	3 m
22	Any Cantilever corridors	nil
23	Number of Exits	one
24	There is high tension electricy lines passing near to the building	-
25	There is Petrol/Gas stations near to the school	-
26	Building Plan submitted	Yes,Plan enclosed
27	Building Foundation and structural design submitted	-
28	Building was last painted in the year	new construction

Certified that the CHITTURI VIDYALAYAM (Block-II) building structutre is fit to run educational institution and this certificate is valid for the period of three year i.e from 17-02-2025 to 16-02-2028

  
 Assistant Executive Engineer  
 (R&B) City Roads Section  
 Vijayawada

  
 Secretary & Correspondent  
**CHITTURI VIDYALAYAM**  
 21-122/15, Panta Kaluva Road,  
 Gollapudi -521225,



  
 Executive Engineer  
 (R&B) Division, Vijayawada.

**For CHITTURI VIDYALAYAM**

  
**PRINCIPAL**