

Government of Andhra Pradesh**A.P. State Disaster Response and Fire Services Department****Periodical Renewal Fire Certificate**

From:
Regional Fire Officer
Zone-2,Rajahmundry
Andhra Pradesh.

To:
DEO,

File No: 31816/NTR/RFO/2026, Date:13/05/2026
Occupancy NOC RC Number: 26069/NTR/MSB/2025

Sir,

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Periodical Fire Certificate to the existing Non Multi Storeyed Building of **M/S. CHITTURI VIDYALAYAM, represented by CHITTURI ANANDA RAMA SUDHAKAR, D.NO.21-122/15, GOLLAPUDI VILLAGE & GRAM PANCHAYAT, VIJAYAWADA RURAL MANDAL, NTR DISTRICT-521225 -** Regarding.

- Ref:
1. G.O.Ms.NO.218 Home (Prisons & Fire) Department, Dated.22-12-2023
 2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.02-05-2023.
 3. This Office NOC for Occupancy Rc No. 26069/NTR/MSB/2025, Dt.24/04/2025
 4. Renewal NOC For Occupancy 26069/NTR/MSB/2025, Dt.24/04/2025
 5. Online Application for Renewal NOC of CHITTURI ANANDA RAMA SUDHAKAR, D.NO.21-122/15, GOLLAPUDI VILLAGE & GRAM PANCHAYAT, VIJAYAWADA RURAL MANDAL, NTR DISTRICT-521225 - Inspection report called for Regarding.
 6. Online Inspection Report submitted by Officers of this Department on 13-05-2026.

-- x --

The Management of M/S. CHITTURI VIDYALAYAM, represented by CHITTURI ANANDA RAMA SUDHAKAR, D.NO.21-122/15, GOLLAPUDI VILLAGE & GRAM PANCHAYAT, VIJAYAWADA RURAL MANDAL, NTR DISTRICT-521225 has requested to issue Periodical Fire Certificate duly remitting the Fire Precautionary fee for Rs.229250/- vide challan No. 11053708742026, Dated 09/05/2026 at online, online.

M/S. CHITTURI VIDYALAYAM

1. This certificate is being issued as per G.O.Ms.No:218,Home(Prisons & Fire),Dt:22-12-2023
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Periodical Renewal Fire Certificate for vide reference 4th cited to the existing Non Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Periodical Renewal Fire Certificate **CHITTURI ANANDA RAMA SUDHAKAR D.NO.21-122/15, GOLLAPUDI VILLAGE & GRAM PANCHAYAT, VIJAYAWADA RURAL MANDAL, NTR DISTRICT-521225**, subject to the following conditions.

Sl	As Builder	As Occupant	As Security Personnel
----	------------	-------------	-----------------------

1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

The applicant/management must train 40% of their total work force on 3 days Basic Firefighting Course under AP Fire Services and Civil Defence Training Institute, Sattenapalli or Regional Training Centres of the Department.

4. This Periodical Renewal Fire Certificate is valid from 24/04/2026 to 23/04/2031.
5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.

6. Challan Info:

Challan Number	Challan Date	Challan Amount
11053708742026	2026-05-09	229250

The following deficiencies/suggestions are identified by the officers of the department and needs to be attended to by the management.

The Inspection committee of DDRFO-NTR and FSI0- Kothapeta inspected the building and the remarks are : Recommended : Sir, submitted that the management has obtained occupancy NOC on 24.04.2025 vide file no26069/NTR/MSB/2025 of the Director General, State Disaster Response and Fire Servics, A.P., Vijayawada. The inspection committee inspected the existing educational building of Ground+3 Upper Floors with height of 12.90 Mtrs. The Building has provided with 4 internal staircases from ground floor to terrace floor with a width of 01.30 Mtrs-2 Nos & 0.80 Mtrs-2 Nos. The building is provided with Extinguishers, Hose Reel System, Down Comer, Mannual Call Point, Terrace Water Tank of 40000 Ltrs and Booster Pump of 450 LPM-02 Nos. The inspection committee tested the fire equipment and found in working condition. The inspection committee conducted awarness programme and mock drill and demonstrated use of fire fighting equipment to the staff.

13/05/26

"Safe School, Safe Hospital & Fire Safety Society-Together for Fire Prevention"**"सुरक्षित विद्यालय, सुरक्षित अस्पताल एवं अग्नि सुरक्षा के प्रति जागरूक समाज आग की रोकथाम के लिए एक साथ"****"సురక్షిత పాఠశాలలు, సురక్షిత మైన ఆసుపత్రులు మరియు అగ్నిమాపక భద్రతపై స్పృహ ఉన్న సమాజం మంటలను నివారించడానికి కలిసి పనిచేస్తాయి."**

Your Sincerely,

Regional Fire Officer
Zone-2, Rajahmundry
Andhra Pradesh.

In case of emergency, please call 101 or 0866-2514851 or 9963728051

Copy to CHITTURI ANANDA RAMA SUDHAKAR, D.NO.21-122/15, GOLLAPUDI VILLAGE &
GRAM PANCHAYAT, VIJAYAWADA RURAL MANDAL, NTR DISTRICT-521225

Copy to Chief Office for Record Purpose

Copy to District Fire Officer Concerned

Copy to Assistant District Fire Officer Concerned

Copy to Station Fire Officer Concerned